

WATER ENGINEERING
STANDARD SUPPLEMENTARY SPECIFICATION HYDROSTATIC TESTING OF PIPELINES

Section 02515S

HYDROSTATIC TESTING OF PIPELINES

The following supplement modifies Specification Section 02515 – Hydrostatic Testing of Pipelines Standard Specification. Where a portion of the Specification is modified or deleted by this Supplementary Specification, the unaltered portions of the Specification shall remain in effect.


3.01 PREPARATION: Delete Paragraph 3.01 D and replace with the following:

“D. Test pipelines in lengths between valves or plugs, maximum lengths meeting the following criteria:


1. 1,500 linear feet for small diameter pipelines (20-inches in diameter or smaller)
2. 4,400 linear feet for large diameter pipelines (24-inches in diameter or larger)”.

END OF SUPPLEMENT

Approved by:



Harish Jajoo, P.E.
Senior Assistant Director
Engineering Branch
Engineering and Construction Division



Date